ISAC Storage Vault Status as of Fe	ebruary 3 2014
------------------------------------	----------------

T					Vault Status as of Februa	-		
Tray #	Pail #	Target	Installed (m/d/y)	Reading (mSv/Hr)	Comments	Date Removed	Reading(mSv/Hr)	Comments
						_		
1A								
1B	94	SiC #26	05/05/12	118mSv/hr				
1C						-		
2A						-		
			10/08/13	24.7mSv/hr				
2B	109	SiC #29	10,00,10			-		
	100	510 11 20	05/31/13	24.8mSv/hr				
2C	105	SiC #28	00/01/10	27.01107/11		-		
20	105	010 #20						
3A	96	SiC #27	07/06/12	178mSv/hr		-		
JA	90	310 #21	09/29/11	111mSv/hr				
20	00	To #20			Asserved			
3B	90	Ta #36	06/20/13	4.64mSv/hr	Assayed			
			11/22/13	76.4mSv/hr		_		
3C	111	NiO#2						
						_		
4A								
4B	104	TiC #3	01/15/13	98.7mSv/hr				
4C	106	Ta #39	07/02/13	95.3mSv/hr				
5A	107	Ta #40	07/29/13	224mSv/hr]		
5B						1		
			06/11/12	152mSv/hr				
5C	95	Nb #6				1		
All readings are taken at 1m from centre of pail. Sealant (111) is used under lid rim. No contamination found unless other wise noted.								
All lids have the lever lock ring and cable lifting setup. This ring must be locked with a thin piece of metal before shipping.								

Tray #	Pail #	Target	Installed (m/d/y)	Reading (mSv/Hr)	Comments	Date Removed	Reading(mSv/Hr)	Comments
			11/09/12	178mSv/hr				
6A	103	Nb # 7						
			08/02/12	226 mSv/hr	Bolts might be contaminated			
6B	97	Ta#38						
			07/25/11	411mSv/hr				
6C	88	Ta#35	06/20/13	8.26mSv/hr	Assayed			
			12/09/13	536mSv/hr	Pail is unnumbered			
7A	112	Ta #41						
7B								
7C					Describle second stice			
0.4	110	110	04/00/44	0.00	Possible conmination			
8A	113	UCx #8	01/22/14	9.20 mSv/hr	on the pail			
8B	110	LICy #7	10/24/13	22.6 mSv/hr				
õБ	110	UCx #7	08/28/13	23.1mSv/hr				
8C	108	UC _x #6	00/20/13	23.11157/11				
Tray #			Date Installed	Reading (mSv/Hr)	Comments	Date Removed		Comments
Tray #	Description of ItemUsed source tray		Date Installeu	5.6 to 16.4	Tray surveyed on	Date Removed	Reading(mSv/Hr)	Comments
		TM #2		mSv/hr thru	11/02/12			
				360°	2.07 to 4.39 mSv/hr			
					though 360°			
					though 500			
9			01/15/09					
0	Used so	ource tray	01/10/09	1.66 to 3.50	The source tray was			
		TM #1		mSv/hr thru	taken apart for inspection			
				360°	Tray surveyed on			
					11/02/12			
			•		1.83 to 3.23 mSv/hr	•		
10			05/12/11		though 360°			
-	All readings are taken at 1m from centre of pail. Sealant (111) is used under lid rim. No contamination found unless other wise noted.							
	All lids have the lever lock ring. This ring must be locked with a thin piece of metal before shipping.							