


TM4 STEEPERS March 31 2021



Megohmmeter Check, with Amprobe Digital Megohmmeter  
AMB-25  
@ 1000 V

	1	2	3	4	Ground
1	■	OL	OL	OL	OL
2		■	OL	OL	OL
3			■	OL	OL
4				■	OL
Ground					■

Continuity Check with Tektronix PMM916

- 1 Passed
- 2 Passed
- 3 Passed
- 4 Passed

- 1-shield to Ground - Passed
- 2-shield to Ground - Passed
- 3-shield to Ground - Passed
- 4-shield to Ground - Passed

Resistance Check with Extech Micro-Ohm meter UM200

- 1 - 232.84 mΩ
- 2 - 231.80 mΩ
- 3 - 232.51 mΩ
- 4 - 231.48 mΩ

- Ground Sheath to Ground
- 1 168.25 mΩ
  - 2 168.74 mΩ
  - 3 168.30 mΩ
  - 4 168.63 mΩ